

CQI WATER TREATMENT

11 Cindy Lane, Ocean NJ 07712
PO Box 1140 Oakhurst NJ 07755
Phone (732) 493-4002 Fax (732) 493-4425

Domestic Water Lead (Bp) Testing ***Point Pleasant Beach School District***

Building	Sample Location	Date	Time	Natl. Standard	Detection Level	Result
Board Office Building	Sink	3/30/16	7:15am	0.015mg/l	<15ppb	ND
Board Office Building	Water Fountain	3/30/16	7:15am	0.015mg/l	<15ppb	ND
Antrim School	Cafeteria Sink	3/30/16	7:45am	0.015mg/l	<15ppb	ND
Antrim School	Main Hallway Fountain	3/30/16	7:45am	0.015mg/l	<15ppb	ND
High School	Cafeteria Sink	3/30/16	8:20am	0.015mg/l	<15ppb	ND
High School	3 rd Floor Fountain	3/30/16	8:20am	0.015mg/l	<15ppb	ND

KEY: ND = The level was not detected above the minimum detection level